

Watkins Glen

Central · School · District
Thomas J. Phillips · Superintendent of Schools

High School Lead in Water Test Final Results

On April 28, 2017 the Watkins Glen Central School District had the final two faucets replaced and retested for lead. This was associated with the recent testing on February 13, 2017 of lead in drinking water at the high school. The location of the faucets were in Room 734 and the Faculty's Restroom next to the High School Library.

The results were with numbers below the action level of 15ppb.

The next round of testing will be required in 2020.

	A	B	C
1	sample number	Results (ppb)	location/notes
2	WGE-412-TRS	5	rm 412 toilet rm sink
3	WGE-407-S	6	rm 407 sink
4	WGE-407-TRS	5	Rm 407 toilet rm sink
5	WGE-414-TRS	5	414 toilet rm sink
6	WGE-415-TRS	5	415 toilet rm sink
7	WGE-416-TRS	5	416 toilet rm sink
8	WGE-417-TRS	5	417 toilet rmsink
9	WGE-418-TRS	5	418 toilet rm sink
10	WGE-419-S1	5	419 sink 1 farthest from door
11	WGE-419-S2	5	419 sink 2 nearest door
12	WGE-419-TRS	29	419 closet sink; resampled 12/6/16 =26ppb-remediation=taken out of service
13	WGE-419-WF	5	419 water fountain
14	WGE-403-S	5	403 sink
15	WGE-NO-TRS	46	nurse's office TR sink; resampled 12/6/16=9ppb
16	WGE-NO-S	5	sink in main office
17	WGE-PO-TRS	5	Principals office TR sink
18	WGE-WR-TRS	5	work rm toilet rm sink
19	WGE-429-S	5	429 sink
20	WGE-429-TRS	5	429 toilet rm sink
21	WGE-431-S	5	431 sink
22	WGE-431-TRS	5	431 toilet rm sink
23	WGE-433-S	7	433 sink
24	WGE-433-TRS	6	433 toilet rm sink
25	WGE-435-S	5	435 sink
26	WGE-435-TRS	5	435 toilet rm sink
27	WGE-437-TRS	5	437 toilet rm sink
28	WGE-436-S-	5	436 sink
29	WGE-436-TRS	5	436 toilet rm sink
30	WGE-434-S	6	434 sink
31	WGE-434-TRS	5	434 toilet rm sink
32	WGE-432-S	5	432 sink
33	WGE-432-TRS	5	432 toilet rm sink

	A	B	C
34	WGE-430-TRS	5	430 toilet rm sink
35	WGE-428-S	5	428 sink
36	WGE-428-TRS	5	428 toilet rm sink
37	WGE-438-S	6	438 sink
38	WGE-438-TRS	8	438 toilet rm sink
39	WGE-440-S	5	440 sink
40	WGE-440-TRS	8	440 toilet rm sink
41	WGE-439-S	5	439 sink

	A	B	C
42			
43	sample number	Results (ppb)	location/notes
44	WGE-439-TRS	5	439 toilet rm sink
45	WGE-441-TRS	5	441 toilet rm sink
46	WGE-K-S1	5	Kitchen sink 1 farthest from door
47	WGE-K-S2	5	Kitchen sink 2 next
48	WGE-K-S3	5	Kitchen sink 3 nearest door
49	WGE-K-TRS	14	Kitchen toilet rm sink
50	WGE-WF-1	5	Water foountain 1
51	WGE-MTR1-S	9	mens staff toilet rm 1 sink
52	WGE-449-TRS	33	449 toilet rm sink;resampled 12/6/16=3ppb
53	WGE-451-TRS	10	451 toilet rm sink
54	WGE-456-S	5	456 sink
55	WGE-456-WF	5	456 water fountain
56	WGE-455-S	5	455 sink
57	WGE-455-WF	5	455 water fountain
58	WGE-457-S	5	457 sink
59	WGE-457-WF	5	457 water fountain
60	WGE-458-S	5	458 sink
61	WGE-458-WF	5	458 water fountain
62	WGE-MTR2-S1	5	mens toilet rm 2 sink 1 farthest from door
63	WGE-MTR2-S2	5	mens toilet rm 2 sink 2 next
64	WGE-WTR2-S1	5	womens toilet rm 2 sink 1 farthest from door
65	WGE-WTR2-S2	5	womens toilet rm 2 sink 2 next
66	WGE-MCO-TRS1	5	men's coaches office TR sink1 farthest from door
67	WGE-MCO-TRS2	5	men's coaches office TR sink2 nearest
68	WGE-WCO-TRS1	5	women's coaches office TR sink 1 farthest from door
69	WGE-WCO-TRS2	5	women's coaches office TR sink 2 nearest door
70	WGE-GymR-WF1	5	facing far end of gym front of FH-WF on left
71	WGE-GymR-WF2	5	facing far end of gym front of FH-WF on right
72	WGE-GymL-WF1	5	facing far end of gym back of FH-WF on left
73	WGE-GymL-WF2	5	facing far end of gym back of FH-WF on right
74	WGE-Ugym-WF1	5	upper level gym far side WF1 left

	A	B	C
75	WGE-Ugym-WF2	5	upper level gym far side WF2 right
76	WGE-MTR3-S1	10	mens toilet rm 3 sink 1 farthest from door
77	WGE-MTR3-S2	5	mens toilet rm 3 sink 1 farthest from door
78	WGE-MTR3-S3	5	mens toilet rm 3 sink 1 farthest from door
79	WGE-MTR3-S4	6	mens toilet rm 3 sink 1 farthest from door
80	WGE-MTR3-S5	7	mens toilet rm 3 sink 1 farthest from door
81	WGE-FH-WF1	5	water fountain farthest from Men's room door
82	WGE-FH-WF2	5	water fountain nearest Men's rm door
83	WGE-WTR3-S1	5	womens toilet rm 3 sink 1 farthest from door
84	WGE-WTR3-S2	5	womens toilet rm 3 sink 1 farthest from door
85	WGE-WTR3-S3	5	womens toilet rm 3 sink 1 farthest from door
86	WGE-WTR3-S4	5	womens toilet rm 3 sink 1 farthest from door
87	WGE-WTR3-S5	5	womens toilet rm 3 sink 1 farthest from door

	A	B	C
88			
89	sample number	Results (ppb)	location/notes
90	WGE-503-S	5	rm 503 sink
91	WGE-504-S	5	rm 504 sink
92	WGE-506-S	5	rm 506 sink
93	WGE-508-S	5	rm 508 sink
94	WGE-507-S	5	rm 507 sink
95	WGE-510-S	5	rm 510 sink
96	WGE-509-TRS	5	rm 509 toilet rm sink
97			
98	sample number	Results (ppb)	location/notes
99	WG-FH-BLR-S1	65	sink 1-farthest from door aerator broken; resampled 1/5/17=1ppb
100	WG-FH-BLR-S2	3	field house boys locker rm sink 2-nearest door
101	WG-FH-GLR-S1	2	Field house Girls locker rm sink 1 farthest from door
102	WG-FH-GLR-S2	5	Field house Girls locker rm sink 2 next to door
103	WG-HS-IM	<1	on pool hallway FH IM inaccessible-locked by Boosters
104	WG-HS-PBLR-S1	2	pool boys locker rm sink 1 farthest from door
105	WG-HS-PBLR-S2	2	pool boys locker rm sink 2 next
106	WG-HS-PBLR-S3	62	pool boys locker rm sink 3 next; resampled 1/5/17=1ppb
107	WG-HS-PGLR-S1	7	pool girls locker rm sink 1 farthest from door
108	WG-HS-PGLR-S2	3	pool girls locker rm sink 2 next
109	WG-HS-PGLR-S3	4	pool locker rm sink 3 next
110	WG-HS-WF1	1	outside of café the one on the left
111	WG-HS-WF2	<1	outside of café, right
112	WG-HS-K-PS1	1	steam pots
113	WG-HS-K-PS2	2	steam pots
114	WG-HS-K-TRS	13	kitchen toilet rm sink
115	WG-HS-K-S1	8	handsink 1
116	WG-HS-K-S2	2	kitchen sink 2
117	WG-HS-K-S3	<1	kitchen sink 3
118	WG-HS-K-S4	<1	kitchen sink 4
119	WG-HS-K-S7	10	handsink 2
120	WG-HS-760-S	1	fac. Lounge sink

	A	B	C
121	WG-HS-WF3	<1	past faculty rm on left before double doors (Left fountain)
122	WG-HS-WF4	<1	right fountain
123	WG-HS-763-BTR-S1	16	sink farthest from door; resampled 1/5/17=8ppb
124	WG-HS-763-BTR-S2	18	boys toilet room adjacent to 763 next sink; resampled 1/5/17<1ppb
125	WG-HS-763-BTR-S3	1	next
126	WG-HS-763-BTR-S4	74	next; resampled 4/20/17 =1 ppb
127	WG-HS-763-GTR-S1	7	gilrs toilet rm adjacent to 763 sink farthest from door
128	WG-HS-763-GTR-S2	2	next
129	WG-HS-763-GTR-S3	1	next
130	WG-HS-763-GTR-S4	2	next

	A	B	C
131			
132	sample number	Results (ppb)	location/notes
133	WG-HS-735-S	<1	workroom behind main office
134	WG-HS-NO-TRS	3	nurse's office toilet rm sink
135	WG-HS-NO-S1	1	nurses office sink 1 farthest from door
136	WG-HS-NO-S2	4	next
137	WG-HS-731-S1	6	home ec sink 1 farthest from door
138	WG-HS-731-S2	10	next
139	WG-HS-731-S3	10	next
140	WG-HS-731-S4	12	next
141	WG-HS-731-S5	3	next
142	WG-HS-734-S	22	rm 734 sink ; resampled 4/28/17=11 ppb
143	WG-HS-734-TRS	5	rm 734 toilet rm sink
144	WG-HS-734-WF	<1	rm 734 water fountain
145	WG-HS-779-S1	N/A	Large STEM lab-sink farthest from door-out of service
146	WG-HS-779-S2	2	next
147	WG-HS-779-S3	9	next
148	WG-HS-FTRS	28	fac.TR off library hall; resampled 4/28/17= 11 ppb
149	WG-HS-Admin-S1	<1	admin sink 1
150	WG-HS-Admin-TRS	145	admin toilet rm sink; resampled 1/5/17=3ppb
151	WG-MS-205-Brkrm-S	67	205 brkrm sink; resampled 4/20/17=2 ppb
152	WG-HS-720-WF	1	water fountain adjacent to 720
153	WG-HS-816-BTRS	25	boys tr rm sink ad. to 816 psych office; resampled 1/5/17=2ppb
154	WG-HS-816-GTRS	21	gilrs toilet rm sink adjacent to 816; resampled 1/5/17=2ppb
155	WG-HS-747-S	3	rm 747 sink
156	WG-HS-747-PS	18	rm 747 prep sink; resampled 1/5/17=20/1ppb-posted pnd'g cap proj.
157	WG-HS-745-S	9	rm 745 sink
158	WG-HS-743-S	60	rm 743 sink; resampled 1/5/17=3ppb
159	WG-HS-715-WF	<1	rm 715 water fountain
160	WG-HS-715-S1	<1	rm 715 sink
161	WG-HS-715-S2	<1	
162	WG-HS-717-WF	N/A	water fountain adjacent to 717 out of service
163	WG-HS-700-S	<1	Music suite

	A	B	C
164	WG-HS-700-WF1	<1	nearest sink
165	WG-HS-700-WF2	<1	farthes from sink
166	WG-HS-704-S1	4	Art rm
167	WG-HS-704-S2	7	rm 704 sink 1 farthest from door
168	WG-HS-704-S3	5	rm 704 next sink clock-wise
169	WG-HS=704-S4	7	rm 704 next sink clock-wise
170	WG-HS-704-S5	4	rm 704 next sink clock-wise
171	WG-HS-704-S6	6	rm 704 next sink clock-wise
172	WG-HS-705-S	29	sink in office area; resampled 1/5/17=3ppb
173	WG-HS-FTR2-S	18	faculty tr 2 adj to boiler rm by aud; resampled 1/5/17=2ppb
174	WG-HS-CLR1-S	12	coaches locker rm sink 1
175	WG-HS-CLR2-S	2	nearest track
176	sample number	Results (ppb)	location/notes

	A	B	C
177	WG-HS-MTR-760-S	5	next to fac. Rm
178	WG-HS-WTR-760-S	13	next to fac. rm
179	WG-HS-HB-1	7	hose bib 1-elementary adj to office
180	WG-HS-HB-2	67	hose bib 2-K wing elem; resampled 1/5/17=6ppb
181	WG-HS-HB-3	8	hose bib 3-outdoor TRs @ football field left
182	WG-HS-HB-4	23	hose bib 4-outdoor TRs @ football field right; permanently out of service 1/5/17
183	WG-HS-OC-sink	21	outdoor concession sink; resampled 4/13/17= 4ppb
184	WG-HS-ODTR-WF1	<1	outdoor toilet rm water fountain on left
185	WG-HS-ODTR-WF2	<1	outdoor toilet rm water fountain on right
186	action level>15ppb		
187	current as of 5/4/17-LJD		
188			